

To: Lukas, David[DLukas@mrbgroup.com]
From: Donohue, Joyce
Sent: Fri 3/20/2015 3:55:27 PM
Subject: RE: PFOA- Hoosick Falls,N.Y.
[image002.jpg](#)

Dear David:

I tried calling you and could not get an answer. You can call me today at 703-491-2070. I am sorry that I did not have an opportunity to return your call yesterday.

Joyce Donohue

From: Lukas, David [DLukas@mrbgroup.com]
Sent: Thursday, March 19, 2015 5:12 PM
To: Donohue, Joyce
Subject: PFOA- Hoosick Falls,N.Y.

Good Afternoon,

The village of Hoosick Falls, N.Y. has recently found that there is PFOA in the municipal water wells that supply the village. The levels are in the range of 300 to 550 ppt (parts per trillion).

Your name was given to the mayor of Hoosick Falls from the State of N.Y.DOH as the resident expert in the EPA on the poly fluoro compound family.

Presently the village has tries to oxidize the PFOA which failed and then to add PAC (poly aluminum chloride) to settle it out. This too had little effect. We will be piloting a G.A.C. test unit shortly .

The village presently is in dire need of any and all financial support and technical assistance that you may be able to give. They have 2 large bonds outstanding for the water and wastewater plants, have to replace a questionable force main and pump station and just found out about the PFOA in November 2014.

My phone number is 518-686-0951 if you would like to converse.

Thank you

David Lukas
Senior Process Manager

[cid:image002.jpg@01D06267.D9E213D0]<<http://www.mrbgroup.com/>>
ALBANY – AUSTIN – CORNING – ROCHESTER – WATERTOWN
125 High Rock Aveue
Saratoga Springs, NY 12866
(518) 899-2180 Phone
(585) 381-1008 Fax

The content of this email is the confidential property of MRB Group and should not be copied, modified, retransmitted, or used for any purpose except with MRB Group's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.